



Suggested Specifications

Rev. 03/14

BELOW GRADE

All drain, waste, vent, sewer and storm lines shall conform to the requirements of CISPI Standard 301*, ASTM A 888* or ASTM A74*. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute or receive prior approval of the engineer.

Building or house sewers shall be of cast iron soil pipe and fittings from the building drain to the point of connecting with the city sewer or private disposal plant. All pipe and fittings shall conform to the requirements of CISPI Standard 301*, ASTM A 888* or ASTM A74*. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute or receive prior approval of the engineer.

ABOVE GRADE

All drain, waste, vent, sewer and storm lines shall conform to the requirements of CISPI Standard 301*, ASTM A 888* or ASTM A 74*. Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute or receive prior approval of the engineer.

JOINTS

- No-Hub Couplings shall conform to the CISPI 310* Standard and ASTM A1277.
- Heavy-Duty Couplings shall conform to the requirements of ASTM C1540.
- Compression Gaskets for Hub & Spigot shall conform to the requirements of ASTM Standard C 564* and ASTM C1563*.
- Joints for pipe and fittings shall conform to the manufacturer's installation instructions and local code requirements.

* Most current edition



CISPI



CERTIFIED



IAPMO



100% RECYCLED



MADE IN USA