



SUGGESTED SPECIFICATIONS

BELOW GRADE

ALL cast iron drain, waste, vent, sewer, and storm lines shall conform to the requirements of CISPI Standard 301", ASTM A888" or ASTM A74". Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute and be listed by NSF International.

ABOVE GRADE

ALL cast iron drain, waste, vent, sewer, and storm lines shall conform to the requirements of CISPI Standard 301", ASTM A888" or ASTM A74". Pipe and fittings shall be marked with the collective trademark of the Cast Iron Soil Pipe Institute and be listed by NSF International.

JOINTS

- No-Hub Couplings shall conform to the CISPI 310" Standard and ASTM A1277 and be listed by NSF International.
- Heavy-Duty Couplings shall conform to the requirements of ASTM C1540.
- Compression Gaskets for Hub & Spigot shall conform to the requirements of ASTM Standard C564" and ASTM C1563".
- Joints for pipe and fittings shall conform to the manufacturer's installation instructions and local code requirements.

, Most current edition

For more information, please contact:

www.mcwanepumbingtechservices.com

www.abifoundry.com 800-468-4766

